



Talibuddin Syed
<talibs@ecentral.com>

02/10/2003 01:41 PM

To: Thor Cutler/R10/USEPA/US@EPA

cc:

Subject: Quil Ceda Village WWTP Effluent Parameters

Thor,

The following parameters need to be considered as Target Compounds in addition to the ones listed by Parametrix in Table 2-2 in their Sampling and Analysis Plan and QAPP dated 1/3/03.

- Organic Chemical - Acrylamide (Generally added during sewage/wastewater treatment)
- Organic Chemical - Benzo(a)pyrene (PAHs) - source is leaching from linings of water storage tanks and distribution lines
- Organic Chemical - Epichlorohydrin - an impurity of some water treatment chemicals

What about radionuclides - Alpha/Beta and Ra-226/Ra228 combined ?

Otherwise, the QAPP and SAP look fine.

Thanks,

Talib Syed, P.E.

2/11/03

Respond whether it will serve
a useful purpose for
providing a baseline